



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312307000204

Applicant	HKC Co., Ltd.
Address	26, Emtibeui 28-ro, Siheung-si, Gyeonggi-do, 15119, Republic of Korea
Manufacturer	HKC Co., Ltd.
Address	26, Emtibeui 28-ro, Siheung-si, Gyeonggi-do, 15119, Republic of Korea
Production Factory	HKC Co., Ltd.
Production Address	26, Emtibeui 28-ro, Siheung-si, Gyeonggi-do, 15119, Republic of Korea
Product	Quarter turn electric actuator
Model/Type	HQ-006
Ex marking	Ex db IIB T4 Gb
Reference Standards	GB/T3836.1-2021, GB/T3836.2-2021

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (1 page).

Initial issue date: 2021-04-23

Issued date: 2023-03-13

Valid to: 2026-04-22

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0001864



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312307000204

Page 1 of 1

Product information:

1. This certificate covers the following models:
 - HQ-006 110 / 220V AC 1 Ph 60/50Hz, 24 V AC/DC
 - Ex marking: Ex db IIB T4 Gb
 - Producers should organize production in accordance with the technical documents approved by the certification body.
2. Specific conditions of safety use:
 - A repair of flameproof joints is not allowed.
 - Ambient temperature range is -20°C...+60°C.
 - Cable entry holes are provided as specified on the CCC certified drawings for the fitting of suitable certified flameproof cable entry devices. Unused entries are to be fitted with suitable CCC certified flameproof blanking plugs.
 - See instruction for other information.
3. Certificate related report(s):
 - Type test report: CQST2103C019, CQST2103C019/01
 - Factory inspection report: CN2021Q010126
4. Certificate change information:
 - 1st change on March 13, 2023: Updated the standards for certification.

Issued date: 2023-03-13

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734

Email: ccc@cn-ex.com